

From

F.S.O.
JIND

To

M/s JASMER SINGH
VILL. SINDHVI KHERA, JIND

Memo No. FS/2021/00257 Dated 05/02/2021

Subject:

No objection Certificate from the Fire Safety Point of View of the KHARAK RAMJI ROAD VILL SINDHVI KHERA DISTT JIND for GURUKULAM GLOBAL SCHOOL.

Reference your letter no. 110212127000138 dated 29/01/2021 on the subject cited above.

Your site for the fire NOC has been inspected by the Team of Fire Station Officers, Jind, from fire safety Point of View. The means of escape and Fire Protection system were checked and found as per the N.B.C. 1983 part IV revised 2005 guideline.

In view of the satisfactory fire protection system/ arrangement mentioned as above, this office has No objection for occupation of Building from the Fire Safety point of view, with the following conditions:-

- 9) The owner/occupier shall keep dully trained Fire Staff in all three shifts.
- 10) The Fire Protection System tested during inspection shall be maintained properly & always should be in good working condition.
- 11) If any lapse is found in the fire protection system at the time of inspection or detected during outbreak of fire, action will be taken as per ruled against you.
- 12) You are directed to apply for NOC in future before 2 month of expiry of your NOC in prescribed Performa.
- 13) The open set back area is not checked at our end as it shall be checked by concerned building authority/department.
- 14) The owner/occupier shall strictly follow the other applicable rules/regulations/byelaws laid down regarding fire safety system. If you fail to comply with any of the above terms & conditions you will be liable to be punished as per Fire Act 2009 specially chapter-III Section 31 Sub-Section 1 & 2 of Fire Act 2009.
- 15) You have to perform quarterly Fire Drill in your building as per NBC with intimation to Fire Department and video graphy evidence to be kept as a record which shall be produced at the time of next Renewal; Residents/R.W.A. shall be involved in the drill.
- 16) If the Infringements of Byelaws remains un- noticed the Authority reserves the right to amend the NOC as and when any such. Infringements comes to notice after giving an opportunity of being heard and the Authority shall stand indemnified against any claim on this account.

The above NOC is valid for only one year from the date of issue of this letter Applying renewal of the same well in time shall be the responsibility of owner/occupier.

Endst. No: FS/2021/00257 Dated 05/02/2021.

A copy if forwarded in reference of Memo No. FS/2021/0010175 Dated 04/02/2019 to the File Station Officer Jind, for information and necessary action please.

Swami Dayanand Edu. Society
U/E., JIND (Haryana)

Krishan Chand
Fire Station Officer
JIND
Fire Station Officer,
Jind

Krishan Chand
Fire Station Officer
JIND
Fire Station Officer,
Jind
Headmaster
Gurukulam Global School
Shri. A. Khera (Jind) Hr.



Digitally signed by KRISHAN
CHAND
Date: 2021.02.05 14:34:21 +05:30
Reason: Digital Verification